



NOTES:

1. FORM LUMBER FOR TREE WELL SHALL BE 2" X 4".
2. NO TREE WILL BE PLANTED UNLESS WATER IS PROVIDED TO PLANTER AREA.
3. 1" CONCRETE CAP IS REQUIRED WHEN TREE PLANTING IS NOT IN CONJUNCTION WITH PROJECT.
4. ALL DRIP SYSTEMS SHALL BE EQUIPPED WITH 200 MESH FILTER, PRESSURE REGULATOR, AND A CLEAN OUT TO FLUSH THE SYSTEM ANNUALLY.
5. ALL PLASTIC TUBING UNDER CONCRETE SHALL BE 1/2" PVC CLASS 125 OR BETTER.
6. MINIMUM EMITTER OUTPUT SHALL BE 40 GALLONS A DAY DURING THE MONTHS OF JULY AND AUGUST AND PROPORTIONAL TO CLIMATIC CONDITIONS FOR THE REMAINDER OF THE YEAR.
7. MAINTAIN 4' CLEAR SIDEWALK WIDTH BETWEEN TREE WELL AND BACK OF WALK.